
Electro-Pneumatic Positioner

Series IP8000/8100







Construction 4

| OOHSH GOHOH * | |
|-----------------|------------------------------|
| 0 | 1 Note 1) |
| No terminal box | With terminal box (Exsd2BT5) |

| • | Δ | cce | 200 | or | ies | Note | 2) |
|---|---|-----|-------------|----|-----|------|----|
| • | ~ | | 53 3 | | 163 | | -, |

| Nil | None (Standard) | IP8000 has standard lever for stroke (10 to 85mm) | |
|-----------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|--|
| A Note 3) | ø0.7 Output restriction with pilot valve | Accessory for IP8000, 8100 | |
| B Note 3) | ø1.0 Output restriction with pilot valve | small capacity actuator | |
| С | Fork lever joint M | Accessory for IP8100 | |
| D | Fork lever joint S | Accessory for IF6100 | |
| E Note 4) | To dione de la recimi war lever din | Accessory for IP8000 | |
| F Note 4) | To the transfer of the first transfer of the t | Accessory for IF6000 | |
| G Note 5) | Compensation spring (A) | For IP8000, 8100 | |
| Н | With external scale plate | Accessory for IP8100 | |
| J Note 6) | With opening current transmission (4 to 20mA DC) | Accessory for IP8100 | |

- Note 1) For construction No.1(with terminal box), the ambient and fluid temperatures are as follows:
- Exd2BT5 -20 to 60°C
 Non-explosion proof (non hazardous locations only) -20 to 80°C
 The positioner body is EXd2BT5 labeled.

 Note 2) If two or more accessories are required, the part numbers should be made according to
- alphabetical order. (ex. IP8000-011-AG)

 Note 3) "A" is applied to approx 90cm³-capacity actuator.
- "B" is applied to approx 180cm³-capacity actuator.
- Note 4) Standard lever is not attached.

 Note 5) It is to be used together with "A" or "B" when tending to overshoot by the use of "A" or "B".

 It is mounted to the body as a replacement of the standard compensation spring.
- Note 6) With terminal box, Non-explosion proof. Select "1" for the construction.

Specifications

| Туре | IP8000 | | IP8100 | |
|-----------------------------|------------------------------------------------------------------------------------|-------------------------|--------------------------|--------------------|
| | Lever type le | ver feedback | Rotary type cam feedback | |
| Item | Single action | Double action | Single action | Double action |
| Input current | | 4 to 20mA | DC Note 1) | • |
| Input resistance | 235±15Ω (4 to 20mADC) | | | |
| Supply air pressure | 0.14 to 0.7MPa | | | |
| Standard stroke | 10 to 85mm (Deflection angle 10 to 30°) 60 to 100° Note 2) | | | 00° Note 2) |
| Sensitivity | Within 0.1%F.S. | \ | Within 0.5%F.S | i. |
| Linearity | Within ±1%F.S. | , | Within ±2%F.S | • |
| Hysteresis | Within 0.75%F.S. | 0.75%F.S. Within 1%F.S. | | |
| Repeatability | Within 0.5%F.S. | | | |
| Coefficient of temperature | Within 0.1%F.S. / °C | | | |
| Supply pressure fluctuation | Within 0.3%F.S./0.01MPa | | | |
| Output flow | 80e/min (ANR) or more (SUP = 0.14MPa) | | | |
| Output now | 200ℓ/min (ANR) or more (SUP = 0.4MPa) | | | |
| Air consumption | 5ℓ/min (ANR) or less (SUP = 0.14MPa) | | | |
| All consumption | 11ℓ/min (ANR) or less (SUP = 0.4MPa) | | | |
| Ambient and fluid | -20 to 80°C (Non-explosion proof) | | | of) |
| temperature | -20 to 60°C (Flame proof and explosion proof) | | | |
| Explosion proof | Flame proof and explosion proof construction: Exd2BT5 | | | |
| construction | onstruction (Certificate number: C15916 of Technology Institution of Industrial Sa | | | Industrial Safety) |
| Air port | Rc 1/4 female | | | |
| Electrial connection | G 1/2 female | | | |
| Wiring method | Flame proof packing system, Sealant fitting system (explosion-proof) | | | |
| Wining intention | Resin G 1/2 connector (Non-Explosion proof, option) | | | |
| Exterior covering enclosure | JISF8007, IP65 (conforms to IEC Pub.529) | | | b.529) |
| Material | Aluminum diecast body / epoxy resin | | | sin |
| Weight | With terminal box 2.6kg (None 2.4kg) | | | |

Note 1) 1/2 Sprit range (Standard) Note 2) Stroke adjustment: 0 to 60°C, 0 to 100°C

Explosion Proof

This product has the following approvals. Exd2BT5: Newly established standard based on international (IEC 79)


Use as Exd2BT5

(A) Pressure-proof packing.

As shown below in the chart, use "Cable gland" (option).

(B) Metal Piping.

Attach the sealant fitting near the cable port. (For details, refer to "The guideline on electric equipment explosion proof" published by the Technology Institution of Industrial Safety.)



Cable gland with flame proof packing (Option)

| Part name | Part number | Suited cable outer diameter |
|---------------------|-------------|-----------------------------|
| Flame proof packing | P368010-32 | ø7.0 to ø10.0 |
| connector unit | P368010-33 | ø10.1 to ø12.0 |



Dimensions / IP8100 (Rotary type)

